

CEG/Kagal-Satara /Pkg-1/NH-48/AE-EPC/2024/936

To,

Authorized Signatory
M/s Roadway Solutions India Infra Limited
Plot No.20, Survey No.29, Dhanjibuoy Society,
Behind Bizzbay, Off NIBM Road, Pune-411048.
Email id: ameetgadhoke@yahoo.com
Phone No.: +91 9822979451

Sub: Consultancy Services for Authority's Engineer for supervision of Six laning of Kagal Satara section of NH-48 (old NH-4) [Pkg-I from Km.592.240 to Km.658.000] in the State of Maharashtra to be executed on EPC mode Bharatmala Pariyojana -**Credentials submission for Expansion joints, Bridge Bearings-Source Approval-Reg**

Ref.- 1. NHAHQ LOA to EPC -No. NHAHQ/Tech/MH-/EPC/K-5/Pkg-I/2022/1410 dt.26.08.2022
2. Concession Agreement signed between NHAHQ & RSIL, Pune dt.17.10.2022
3. NHAHQ/TIC/PQ/2012-13/424 dt.12.12.2023
4. RSIL/Pune/CEG/Kagal/2024/Site/3715 Dtd.08.10.2024
5. MoRTH letter No.RW/NH-34054/2/2011-S&R(B) Dt.14.08.2018

Dear Sir,

With reference to the above cited subject and referred letters, the credentials of **M/s Galvano Structures India Pvt. Ltd.**, address from **D-14, Site-B, UPSIDC, Sarjapur, Industrial Area, Greater Noida, Uttar Pradesh, 201306**, India for procurements of Expansion Joint, Bridge Bearings have been submitted for review.

1. The credential submitted by you vide letter reference '4' for the source approval **M/s Galvano Structures India Pvt. Ltd.** for procurements of Expansion Joint, Bearings for Source Approval.
2. The above-mentioned source **M/s. Galvano Structures India Pvt. Ltd** for Expansion Joint, Bridge Bearings are found regulated in terms of Ministry Of Road Transport & Highway reference letter no.5 with fulfill the mentioned subject to condition approval in this circular. The credential of **M/s Galvano Structures India Pvt. Ltd.** Source is hereby approved conditionally.
3. As per guidelines in Section 5, IRC SP:112 as per Clause No. 5.5, the Authority Engineer/Consultants are required to witness a certain percentage of in- House tests conducted by manufacturer/ supplier.
4. Manufacture Test Certificate as well as Third-party Quality test certificate from approved NABL accredited laboratory shall be submitted for each time and each lot procured prior to using in the works. Every lot sampling should be done in presence of AE. This is Mandatory requirement and EPC Contractor has to adhere strictly.
5. A prior intimation shall be made to this office before procurement of the above-mentioned material along with the details.
6. If any test piece selected from a lot fails, no testing shall be done and the entire lot is liable for rejection and source will be disapproved.
7. EPC contractor is advised that to arrange for joint factory visit to review the manufacturing process and testing facilities available to check the suitability of at factory unit for our further review and approval.

This is for your information & necessary action, please.

With Best Regards

For Consulting Engineers Group Ltd. in association with
Shri Kushalsuri Engineering Services Pvt. Ltd.

Milind Shirao
Team Leader cum Senior Highway Engineer
Kagal-Satara Pkg-I

Encl: RSIL/Pune/CEG/Kagal/2024/Site/3715

- CC
1. The Project Director, NHAHQ PIU, Kolhapur - for information, please.
 2. Col. Sanjay Bajpai, Senior Vice President (Head Coordination), CEG, Jaipur- for information
 3. RE/BE/SPS/SQME/AE/site staff- for information & necessary action
 4. Office File